


VINCENT COUNTY COUNCIL

OMAKAU WATER SUPPLY LOAN PROPOSALS

DUFFILL, WATTS & KING
CIVIL ENGINEERS AND SURVEYORS.
DUNEDIN and INVERCARGILL


	NAM	DATE	JOB NO.
	Hannan IRP <u> </u>	Apr '56 = =	2646 / 1
	IRP	May '56	F.B.I. 131 FILE NO. 5/4/15





Elevation

20,000 gall. Steel Water Tower
18'0" 10' 10'0"

Foundation Plan




Superstructure Plan



— SKETCH LAYOUT OF PROPOSED PUMPING STATION —

scale 1/8" to 1'

Pumps : Twin deepwell turbine
Output : 150 g.p.m. at 160 ft.



- PROPOSED RENEWAL OF RETICULATION.-

Approx Water level of Stream at PumpStn 48' above datum

" Ground level of Town (Main St) 60' .. .

" Water level of Reservoir 120' .. .

" Average static pressure in township - 26 lb/sq.in.


Minimum residual pressure at 150 gpm

fire flow = 23 lb/sq.in

Maximum effective capacity of existing reservoir

after repair = 50000 gal

Population 1956 : 70 persons (22 householders).



— PLAN OF TOWNSHIP.

Scale: 2 chains to 1 inch.

Approx Water level of Stream at Pump.Stn 48' above datum

" Ground level of Town (Main St) 60'

" Water level of Reservoir 120'

" Average static pressure in township - 26 lb./sq.in.

Minimum residual pressure at 150 g.p.m

fire flow - 23 lb./sq.in.

Maximum effective capacity of existing reservoir

after repair - 500,000 gal.

Population 1956 : 70 persons (22 householders).

EL. WATTS & KING ENGINEERS AND SURVEYORS EDIN and INVERCARGILL		IN'GILL NO. 7031	JOB-NO. 2646
SURVEYED BY DRAWN CALCULATIONS CHECKED TRACED	DATE Plan ~ <i>measured</i> A.B.Cochran	DATE Aug '57 <i>Jan 67</i> 23-1-1957	A.B.P. 131 FILE NO. S1-1150



