

Certificate of Analysis

Page 1 of 4

Client:	Clark Fortune McDonald & Associates	Lab No:	3456537	DWAPV1
Contact:	Emma Dixon C/- Clark Fortune McDonald & Associates PO Box 553 Queenstown 9348	Date Received:	01-Feb-2024	
		Date Reported:	08-Feb-2024	
		Quote No:		
		Order No:	15707	
		Client Reference:	Double Rock	
		Submitted By:	Emma Dixon	

Sample Type: Aqueous

Sample Name:		Double Rock 31-Jan-2024 12:00 pm		Aesthetic Values	Maximum Acceptable Values (MAV)
Lab Number:		3456537.1			
Routine Water + E.coli profile Kit					
Escherichia coli	MPN / 100mL	43		-	< 1
Routine Water Profile					
Turbidity	NTU	1.83		≤ 5	-
pH	pH Units	8.0		7.0 - 8.5	-
Total Alkalinity	g/m ³ as CaCO ₃	41		-	-
Free Carbon Dioxide	g/m ³ at 25°C	< 1.0		-	-
Total Hardness	g/m ³ as CaCO ₃	41		≤ 200	-
Electrical Conductivity (EC)	mS/m	8.8		-	-
Electrical Conductivity (EC)	µS/cm	88		-	-
Approx Total Dissolved Salts	g/m ³	59		≤ 1000	-
Total Arsenic	g/m ³	0.0066		-	0.01
Total Boron	g/m ³	< 0.0053		-	2.4
Total Calcium	g/m ³	13.2		-	-
Total Copper	g/m ³	< 0.00053		≤ 1	2
Total Iron	g/m ³	0.075		≤ 0.3	-
Total Lead	g/m ³	0.00029		-	0.01
Total Magnesium	g/m ³	1.82		-	-
Total Manganese	g/m ³	0.022		≤ 0.04 (Staining) ≤ 0.10 (Taste)	0.4
Total Potassium	g/m ³	0.74		-	-
Total Sodium	g/m ³	2.2		≤ 200	-
Total Zinc	g/m ³	0.0025		≤ 1.5	-
Chloride	g/m ³	0.9		≤ 250	-
Nitrate-N	g/m ³	< 0.05		-	11.3
Sulphate	g/m ³	2.9		≤ 250	-

Note: The Maximum Acceptable Values (MAV) are taken from the 'Water Services (Drinking Water Standards for New Zealand) Regulations 2022', published under the authority of the New Zealand Government-2022. Copies of this publication are available from: <https://www.legislation.govt.nz/regulation/public/2022/0168/latest/whole.html>

The standards set limits for the concentration of determinands in drinking water. The Maximum Acceptable Values (MAVs) for any determinand must not be exceeded at any time.

The Aesthetic Values are taken the publication, 'Aesthetic Values for Drinking Water Notice 2022' issued by the Water Services Regulator ("Taumata Arowai"). Aesthetic values specify or provide minimum or maximum values for substances and other characteristics that relate to the acceptability of drinking water to consumers (such as appearance, taste or odour).

Note that the units: g/m³ are the same as mg/L and ppm.



This Laboratory is accredited by International Accreditation New Zealand (IANZ), which represents New Zealand in the International Laboratory Accreditation Cooperation (ILAC). Through the ILAC Mutual Recognition Arrangement (ILAC-MRA) this accreditation is internationally recognised. The tests reported herein have been performed in accordance with the terms of accreditation, with the exception of tests marked * or any comments and interpretations, which are not accredited.

pH/Alkalinity and Corrosiveness Assessment

The pH of a water sample is a measure of its acidity or basicity. Waters with a low pH can be corrosive and those with a high pH can promote scale formation in pipes and hot water cylinders.

The guideline level for pH in drinking water is 7.0-8.5. Below this range the water will be corrosive and may cause problems with disinfection if such treatment is used.

The alkalinity of a water is a measure of its acid neutralising capacity and is usually related to the concentration of carbonate, bicarbonate and hydroxide. Low alkalinities (25 g/m³) promote corrosion and high alkalinities can cause problems with scale formation in metal pipes and tanks.

The pH of this water is within the NZ Drinking Water Guidelines, the ideal range being 7.0 to 8.0. With the pH and alkalinity levels found, it is unlikely this water will be corrosive towards metal piping and fixtures.

Hardness/Total Dissolved Salts Assessment

The water contains a very low amount of dissolved solids and would be regarded as being soft.

Nitrate Assessment

Nitrate-nitrogen at elevated levels is considered undesirable in natural waters as this element can cause a health disorder called methaemaglobinaemia. Very young infants (less than six months old) are especially vulnerable. The 'Water Services (Drinking Water Standards for New Zealand) Regulations 2022' sets a maximum permissible level of 11.3 g/m³ as Nitrate-nitrogen (50 g/m³ as Nitrate).

Nitrate-nitrogen was not found in this water.

Boron Assessment

Boron may be present in natural waters and if present at high concentrations can be toxic to plants.

Boron was not detected in this water.

Metals Assessment

Iron and manganese are two problem elements that commonly occur in natural waters. These elements may cause unsightly stains and produce a brown/black precipitate. Iron is not toxic but manganese, at concentrations above 0.5 g/m³, may adversely affect health. At concentrations below this it may cause stains on clothing and sanitary ware.

Iron was found in this water at a low level.

Manganese was found in this water at a low level.

Treatment to remove iron and/or manganese should not be necessary.

Bacteriological Tests

The Drinking Water Standards for NZ state that there should be no Escherichia coli (E coli) in water used for human consumption. The presence of these organisms would indicate that other pathogens of faecal origin may be present.

The E coli result indicates that this water should be checked again ensuring the sample is collected into a sterile container and, if still high, the water should not be used for drinking without filtration or disinfection

Final Assessment

The parameter Escherichia coli did NOT meet the guidelines laid down in the 'Water Services (Drinking Water Standards for New Zealand) Regulations 2022' and the 'Aesthetic Values for Drinking Water Notice 2022' issued by the Water Services Regulator ("Taumata Arowai") for water which is suitable for drinking purposes.

Summary of Methods

The following table(s) gives a brief description of the methods used to conduct the analyses for this job. The detection limits given below are those attainable in a relatively simple matrix. Detection limits may be higher for individual samples should insufficient sample be available, or if the matrix requires that dilutions be performed during analysis. A detection limit range indicates the lowest and highest detection limits in the associated suite of analytes. A full listing of compounds and detection limits are available from the laboratory upon request. Unless otherwise indicated, analyses were performed at Hill Labs, 28 Duke Street, Frankton, Hamilton 3204.

Sample Type: Aqueous			
Test	Method Description	Default Detection Limit	Sample No
Routine Water Profile		-	1
Filtration, Unpreserved	Sample filtration through 0.45 µm membrane filter. Analysed at Hill Laboratories - Chemistry; Unit 1, 17 Print Place, Middleton, Christchurch.	-	1
Total Digestion	Nitric acid digestion. APHA 3030 E (modified) : Online Edition.	-	1
Turbidity	Analysis by Turbidity meter. Analysed at Hill Laboratories - Chemistry; Unit 1, 17 Print Place, Middleton, Christchurch. APHA 2130 B (modified) : Online Edition.	0.05 NTU	1
pH	pH meter. Analysed at Hill Laboratories - Chemistry; Unit 1, 17 Print Place, Middleton, Christchurch. APHA 4500-H ⁺ B (modified) : Online Edition. Note: It is not possible to achieve the APHA Maximum Storage Recommendation for this test (15 min) when samples are analysed upon receipt at the laboratory, and not in the field. Samples and Standards are analysed at an equivalent laboratory temperature (typically 18 to 22 °C). Temperature compensation is used.	0.1 pH Units	1
Total Alkalinity	Titration to pH 4.5 (M-alkalinity), autotitrator. Analysed at Hill Laboratories - Chemistry; Unit 1, 17 Print Place, Middleton, Christchurch. APHA 2320 B (modified for Alkalinity <20) : Online Edition.	1.0 g/m ³ as CaCO ₃	1
Free Carbon Dioxide	Calculation: from alkalinity and pH, valid where TDS is not >500 mg/L and alkalinity is almost entirely due to hydroxides, carbonates or bicarbonates. APHA 4500-CO ₂ D : Online Edition.	1.0 g/m ³ at 25°C	1
Total Hardness	Calculation from Calcium and Magnesium. APHA 2340 B : Online Edition.	1.0 g/m ³ as CaCO ₃	1
Electrical Conductivity (EC)	Conductivity meter, 25°C. Analysed at Hill Laboratories - Chemistry; Unit 1, 17 Print Place, Middleton, Christchurch. APHA 2510 B : Online Edition.	0.1 mS/m	1
Electrical Conductivity (EC)	Conductivity meter, 25°C. APHA 2510 B : Online Edition.	1 µS/cm	1
Approx Total Dissolved Salts	Calculation: from Electrical Conductivity.	2 g/m ³	1
Total Arsenic	Nitric acid digestion, ICP-MS, trace level. APHA 3125 B : Online Edition / US EPA 200.8.	0.0011 g/m ³	1
Total Boron	Nitric acid digestion, ICP-MS, trace level. APHA 3125 B : Online Edition.	0.0053 g/m ³	1
Total Calcium	Nitric acid digestion, ICP-MS, trace level. APHA 3125 B : Online Edition.	0.053 g/m ³	1
Total Copper	Nitric acid digestion, ICP-MS, trace level. APHA 3125 B : Online Edition / US EPA 200.8.	0.00053 g/m ³	1
Total Iron	Nitric acid digestion, ICP-MS, trace level. APHA 3125 B : Online Edition.	0.021 g/m ³	1
Total Lead	Nitric acid digestion, ICP-MS, trace level. APHA 3125 B : Online Edition / US EPA 200.8.	0.00011 g/m ³	1
Total Magnesium	Nitric acid digestion, ICP-MS, trace level. APHA 3125 B : Online Edition.	0.021 g/m ³	1
Total Manganese	Nitric acid digestion, ICP-MS, trace level. APHA 3125 B : Online Edition / US EPA 200.8.	0.00053 g/m ³	1
Total Potassium	Nitric acid digestion, ICP-MS, trace level. APHA 3125 B : Online Edition.	0.053 g/m ³	1
Total Sodium	Nitric acid digestion, ICP-MS, trace level. APHA 3125 B : Online Edition.	0.021 g/m ³	1
Total Zinc	Nitric acid digestion, ICP-MS, trace level. APHA 3125 B : Online Edition / US EPA 200.8.	0.0011 g/m ³	1
Chloride	Filtered sample from Christchurch. Ion Chromatography. APHA 4110 B (modified) : Online Edition.	0.5 g/m ³	1
Nitrate-N	Filtered sample from Christchurch. Ion Chromatography. APHA 4110 B (modified) : Online Edition.	0.05 g/m ³	1
Sulphate	Filtered sample from Christchurch. Ion Chromatography. APHA 4110 B (modified) : Online Edition.	0.5 g/m ³	1
Escherichia coli	MPN count using Colilert 18 (Incubated at 35°C for 18 hours) and 97 wells. Analysed at Hill Laboratories - Microbiology; Unit 1, 17 Print Place, Middleton, Christchurch. APHA 9223 B : Online Edition.	1 MPN / 100mL	1

These samples were collected by yourselves (or your agent) and analysed as received at the laboratory.

Testing was completed between 01-Feb-2024 and 08-Feb-2024. For completion dates of individual analyses please contact the laboratory.

Samples are held at the laboratory after reporting for a length of time based on the stability of the samples and analytes being tested (considering any preservation used), and the storage space available. Once the storage period is completed, the samples are discarded unless otherwise agreed with the customer. Extended storage times may incur additional charges.

This certificate of analysis must not be reproduced, except in full, without the written consent of the signatory.

A handwritten signature in blue ink, consisting of several overlapping, stylized strokes.

Ara Heron BSc (Tech)
Client Services Manager - Environmental